



# VALLEY CENTER FIRE PROTECTION DISTRICT

28234 Lilac Road, Valley Center, CA 92082  
(760) 751-7600 Fax (760) 749-3892  
Website: [vcfpd.org](http://vcfpd.org)



## FINAL AGENDA

### SAN DIEGO COUNTY FIRE APPEALS BOARD

Tuesday, September 16, 2025, 9:00 AM

Coronado Conference Room

5560 Overland Avenue, 4<sup>th</sup> Floor, San Diego, California 92123

1. Chair calls the meeting to order
2. Statement of Fire Appeal Board Proceedings
3. Roll Call
4. Public Communication
5. Requests for Continuance

#### 1. PDS2025-MISC-25-004 Kirklen Fire Appeal

*Applicant is requesting a modification regarding Section 507 of the 2022 California Fire Code, Fire Protection Water Supplies. Applicant is requesting the installation of a water tank in lieu of a fire hydrant. Section 507.5.1 of the CFC states hydrant distance requirement shall be not more than 600'. Under the 2023 Consolidated Fire Code for the Fire Protection Districts in San Diego County, water tanks are only permitted as determined by the fire code official if a letter from the applicable water district is provided stating that the district would not be able to provide service if the water line were extended and a hydrant installed. This letter has not been made available to the District. Therefore, the request has been denied.*

- Presentation from Chief Loffredo of the Valley Center Fire Protection District
- Presentation from Appellant
- Discussion and Questions from the Board to Chief Loffredo or to the Appellant
- Motion and Second by the Board Members
- The secretary takes the vote.

#### 6. **Adjournment Motion**

Valley Center Fire Station 1  
28234 Lilac Road  
Valley Center, CA 92082

Valley Center Fire Station 2  
28205 N. Lake Wohlford Road  
Valley Center, CA 92082